

Building: _____

Date: _____

Room: _____

**MIT HOUSING DEPARTMENT
FIRE SAFETY ROOM INSPECTION REPORT**
Dormitory: Suites, Bedrooms, Bathrooms, Livingrooms

Please correct the following safety hazards found during this inspection:

- Illegal Electrical Appliances/Devices**
Please Remove: _____

- Overloaded Electrical Receptacles**

- Refrigerator:**
MUST be plugged directly into outlet or a heavy- duty extension cord.

- Improper Flammable and Combustible Liquid Storage**

- Remove Candles and/or Oil Lamps**

- Excessive Combustible Items on (circle): Walls/ Ceilings/ Doors/ Floor**
(Combustible Materials Include: Wall Hangings, Tapestries, Flags)
(Must cover no more than 1/3 of available space)

- Bed Too Close to Ceiling**
(Required to have 36 inches between top of mattress and the ceiling or sprinkler head)

- Obstructed Fire Protection Equipment**
Please Remove _____ from _____

- Furniture Directly Against Room Heating Elements/Electrical Service**
(Air Gap Must be Maintained Around Electrical Wiring/Heating Elements)

- Hazardous Materials**
Please remove: _____

- Obstructed Egresses**

- Furniture Inventory**

- Smoke Detector Test**

- Please Remove all Halogen Lamps without Grate**

- Other:** _____

Inspector's Signature: _____